



ENVIRO TECH SERVICES PVT. LTD.

An Analytical Laboratory

(AN ISO 45001:2018 Certified Laboratory)

Plot No. 1/32, S.S. of G.T. Road Industrial Area, Ghaziabad (U.P.) - 201001

email : etslab2012@gmail.com | Website : www.etslab.in | Ph.: 9911516076, 8130255461



TC-15390

TEST REPORT

TEST REPORT NO.: ETS/2112-1/01/2026

ULRNO.TC153902600021121F

DATE OF REPORT: 23.01.2026

WATER SAMPLE ANALYSIS REPORT

Name And Address of Customer

: M/s. OPGM SR SEC SCHOOL MAULAGARH,
BAHJOI ROAD CHANDAUSI (SAMBHAL) UP-244412

Date & Time of Sampling

: 19.01.2026 (10:30 AM)

Analysis Start Date

: 20.01.2026

Analysis End Date

: 23.01.2026

Sample ID No

: 2112-1

Sampling Done By

: ETS STAFF

Sampling Description

: DRINKING WATER

Sampling Location

: FROM R.O

Sampling Method

: IS:17614 (PART-1)

Sample Quantity

: 2.0 + 0.5 Ltr.

Packing Condition

: SEALED

Packed In

: P.V.C. AND GLASS BOTTLE

S. No.	Test Parameter	Unit	Result	Specification/Limit (As per IS:10500: 2012)		Test Method
				Desirable	Permissible	
PHYSICAL & CHEMICAL PARAMETERS;						
1	Colour	Hazen	<5.0	5	15	APHA 2120-B
2	Odour	...	Agreeable	Agreeable	Agreeable	APHA 2150-B
3	Taste	...	Agreeable	Agreeable	Agreeable	APHA 2160-C
4	pH @ 25°C	...	7.03	6.5 - 8.5	No Relaxation	APHA 4500-H+
5	Turbidity	NTU	<1.0	1	5	APHA 2130-B
6	Total Dissolved Solids,(TDS)	mg/L	85.4	500	2000	APHA 2540-C
7	Chlorine (Residual)	mg/L	<0.02	0.2	1	APHA 4500:(Cl)-B
8	Fluoride,(F)	mg/L	<0.01	1	1.5	APHA 4500:(F-)-D
9	Total Alkalinity,(CaCO3)	mg/L	47.3	200	600	APHA 2320-B
10	Calcium,(Ca)	mg/L	14.4	75	200	APHA 3500:(Ca)-B
11	Chloride,(Cl)	mg/L	20.9	250	1000	APHA 4500:(Cl-)-B
12	Sulphate,(SO ₄)	mg/L	8.2	200	400	APHA 4500:(SO ₄)-E
HEAVY METALS;-						
13	Iron,(Fe)	mg/L	<0.05	1.0	No Relaxation	APHA-3120B



For Enviro Tech Services Pvt. Ltd.

AUTHORIZED SIGNATORY

Format No ETS/LAB/TR-09, Issue No. 05, Date 01.04.2019, Amd. No. 04 Date 01.04.2019

Note:-

1. Test reports without ETS LAB HOLOGRAM are not issued by our laboratory.
2. The results indicated only refer to the tested samples and listed applicable parameters.
3. No complaint will be entertained if received after 7 days of issue of test report.
4. Our liability is limited to invoice value only.
5. The sample shall be destroyed after 15 days & Biological / Perishable sample shall be destroyed immediately after issue of test report.
6. This test report shall not be used in any advertising media or as evidence in the court of Law without prior written permission of the laboratory.





ENVIRO TECH SERVICES PVT. LTD.

An Analytical Laboratory



(AN ISO 45001:2018 Certified Laboratory)

Plot No. 1/32, S.S. of G.T. Road Industrial Area, Ghaziabad (U.P.) - 201001

email : etslab2012@gmail.com | Website : www.etslab.in | Ph.: 9911516076, 8130255461




TEST REPORT

TEST REPORT NO.: ETS/2112-1/01/2026

DATE OF REPORT: 23.01.2026

WATER SAMPLE ANALYSIS REPORT

S. No.	Test Parameter	Unit	Result	Specification/Limit (As per IS:10500: 2012)		Test Method
				Desirable	Permissible	
MICROBIOLOGICAL PARAMETER;						
14	Total Coliform	Per 100MI	Absent	Shall Not Be Detectable		IS 15185
15	Escherichia coli	Per 100mL	Absent	Shall Not Be Detectable		IS 15185



For Enviro Tech Services Pvt. Ltd.


Md Humraj
(Quality Manager)

AUTHORIZED SIGNATORY

Format No ETS/LAB/TR-09, Issue No. 05, Date 01.04.2019, Amd. No. 04 Date 01.04.2019

*****End of Test Report*****

Note:-

1. Test reports without ETS LAB HOLOGRAM are not issued by our laboratory.
2. The results indicated only refer to the tested samples and listed applicable parameters.
3. No complaint will be entertained if received after 7 days of issue of test report.
4. Our liability is limited to invoice value only.
5. The sample shall be destroyed after 15 days & Biological / Perishable sample shall be destroyed immediately after issue of test report.
6. This test report shall not be used in any advertising media or as evidence in the court of Law without prior written permission of the laboratory.



(A GOVERNMENT APPROVED LAB)

Plot No. 1/32, S.S. of G.T. Road Industrial Area, Ghaziabad (U.P.) - 201001

email : etslab2012@gmail.com | Website : www.etslab.in | Ph.: 9911516076, 8130255461

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated:

To,
OPGM Sec School
Maulagarh Bahjoi Chandausi Sambhal,
(U.P.)-244412.

It is certified that an inspection team headed by Md.Humraj (Quality Manager) from Enviro Tech Services Pvt. Ltd. (1/32, S.S. of G.T. Road Industrial area, Ghaziabad (U.P.)- 201001) inspected the OPGM Sec School (Maulagarh Bahjoi Chandausi Sambhal (U.P.)-244412) on the basis of Water Test Report (Attached- ETSP certified) that the OPGM Sec School has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the IS 10500:2012.

Signature with Seal:..

For Enviro Tech Services Pvt. Ltd.


Md Humraj
(Quality Manager)

Name : Md Humraj.....

Designation:..Quality Manager.....

The certificate is to be issued by authorized Enviro Tech Services Pvt. Ltd.